

Danish Indoor Climate Labelling

Certificate no. 014



Danish Indoor Climate Labelling hereby certifies that the product group:

Gyproc Wall Systems (untreated surfaces) and Gyproc ACOUnomic Steel Channels

Gyproc
Saint-Gobain Denmark A/S
Hareskovvej 12
4400 Kalundborg
Denmark

Gyproc
Saint-Gobain Byggevarer AS
Habornveien 59
1630 Gamle Frederikstad
Norway

Gyproc
Saint-Gobain Sweden AB
Kalmarleden 50
746 37 Bålsta
Sweden

has been approved and awarded a labelling license

The labelling license is valid through:

30 April 2024


Danish Indoor Climate Labelling

*This certificate is subject to annual renewal according to the procedures of Danish Indoor Climate Labelling.
Danish Indoor Climate Labelling may withdraw the rights to use this certificate in case the manufacturer does not meet the requirements.*

Danish Indoor Climate Labelling

Certificate no. 014

Labelling license holder:

Gyproc

Saint-Gobain Denmark A/S
Hareskovvej 12
4400 Kalundborg
Denmark

Gyproc

Saint-Gobain Byggevarer AS
Habornveien 59
1630 Gamle Frederikstad
Norway

Gyproc

Saint-Gobain Sweden AB
Kalmarleden 50
746 37 Bålsta
Sweden

Product group

**Gyproc Wall Systems (untreated surfaces) and
Gyproc ACOUnomic Steel Channels**

Testing and labelling criteria

General labelling criteria, 6th edition, 2018,
Ceiling and wall systems, 4th edition, 2018
1 May 1995

Date of first issue of license

Tested product(s)

Glasroc H Ocean, Gyproc ErgoLite, Gyproc FireCase, Gyproc Protect F,
Gyproc GRI Robust, Gyproc Habito, Gyproc X-ray Protection

Evaluation of product group

EMISSION CLASS 1

The labelling license covers products considered to be identical with the tested product regarding emission and particle characteristics as specified by the labelling criteria. For a full list of products covered by the labelling license, see Appendix.

The emission class was determined based on the following measured values:

Emission measured after 28 days		
TVOC ₂₈	0.10	mg/m ³
Formaldehyde ₂₈	0.004	mg/m ³
Sensory evaluation		
Time-value	10	days

Labelling license basis

The tested product(s) shows compliance with the DICL criteria for the present product group:

Emission measured after 3 days		
TVOC	≤	10 mg/m ³
EU CARC 1A and 1B	≤	0.01 mg/m ³
Emission measured after 28 days		
Sum of TVOC and SVOC with LCI	≤	1.0 mg/m ³
EU CARC 1A and 1B	≤	0.001 mg/m ³
R-value	≤	1
Sensory evaluation		
Time-value	≤	100 days

Emission Class 1	TVOC ₂₈	≤	0.5	mg/m ³
	Formaldehyde ₂₈	≤	0.01	mg/m ³
Emission Class 2	TVOC ₂₈	≤	1.0	mg/m ³
	Formaldehyde ₂₈	≤	0.06	mg/m ³
Emission Class 3	TVOC ₂₈	≤	1.0	mg/m ³
	Formaldehyde ₂₈	≤	0.1	mg/m ³

Product information requirements

The holder of the labelling license is required to present the following product information on demand in order to avoid any adverse effects of the product on the indoor air quality in practice: product specifications, guidelines for transport, storage, assembly, cleaning and maintenance.

In the event of any discrepancies in the text arising from translation, the Danish text shall prevail.