

## Declaration of Performance

No.: **DoP DK-IP Acrylic 001**

1. Unique identification code of the product-type:

### Isover Protect Acrylic

2. Type, batch or serial no. or any other element allowing identification of the construction product as required pursuant to article 11(4):

**See packaging for batch no.**

2.1 Isover Protect Acrylic is supplied in 300 ml foils, 310 ml cartridges, 380 ml cartridges and 600 ml foils.

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer, and in accordance with the applicable European Assessment Document: EAD 350454-00-1104 (penetration seals) and EAD 350141-00-1106 (linear joint seals):

3.1 The intended use of system Isover Protect Acrylic is to reinstate the fire resistance performance of gaps, joints and penetrating services in and between flexible, timber and rigid wall constructions, and rigid, composite and timber floor constructions, including between timber door/window, aluminium/steel frames and substrates.

3.2 The specific elements of construction that the system Isover Protect Acrylic may be used to provide a gap or joint seal or penetration seal in, are as follows, unless otherwise stated in the following country document approvals:

– EU use only, ETA 24/0364 and ETA 24/0365

Flexible walls: The wall must have a minimum thickness of 75 mm and comprise steel studs lined on both faces with minimum 1 layer of 12.5 mm thick boards <sup>1)</sup>.

Timber walls: The wall must have a minimum thickness of 100 mm and comprise solid wood or cross-laminated timber.

Rigid walls: The wall must have a minimum thickness of 75 mm and comprise concrete, aerated concrete or masonry, with a minimum density of 650 kg/m<sup>3</sup> <sup>1)</sup>.

Rigid floors: The floor must have a minimum thickness of 150 mm <sup>2)</sup> and comprise aerated concrete or concrete with a minimum density of 650 kg/m<sup>3</sup>.

Timber floors: The floor must have a minimum thickness of 150 mm and comprise solid wood or cross-laminated timber.

The supporting construction must be classified in accordance with EN 13501-2 for the required fire resistance period.

<sup>1)</sup> Minimum wall thickness is dependent on approvals specified in the ETAs Annex A.

<sup>2)</sup> Composite floors can be thinner, please refer to the installation instructions.

- 3.3 The system Isover Protect Acrylic may be used to provide a penetration seal with specific single insulated and uninsulated metal and plastic pipes, and with specific electrical cables and conduits, single or in a bundle and may also be used to provide a linear joint or gap seal with specific supporting constructions and substrates. For details refer to the country document approvals:

– EU use only, ETA 24/0364 and ETA 24/0365

The maximum permitted joint/gap width for system Isover Protect Acrylic is 100 mm.

The maximum movement capability of system Isover Protect Acrylic is 12.5%

Services in floors should be supported at maximum 550 mm from the top face. Services in walls should be supported at maximum 350 mm from both faces of the wall.

- 3.4 The provisions made in this DoP are based on an assumed working life of the Isover Protect Acrylic of 10 years, however provided that the conditions laid down in the manufacturers' instructions and datasheet for the packaging/transport/ storage/installation/use/repair are met the assumed working life for Isover Protect Acrylic for internal conditions without exposed to UV or moisture is 30 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

- 3.5 Type Z<sub>2</sub>: intended for use for internal conditions with humidity lower than 85% RH excluding temperatures below 0 °C, without exposure to rain or UV.

4. Name, registered trade name or registered trademark and contact address of the manufacturer as required pursuant to article 11(5):

**Saint-Gobain Denmark A/S**  
**Isover A/S**  
**Østermarksvej 4**  
**6580 Vamdrup**  
**Denmark**  
**Tlf.: +45 72 17 17 17**  
**E-mail: isover@isover.dk**

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

**Not applicable**

6. System or systems of assessment and verification of consistency of performance of the construction product as set out in annex V:

**AVCP-System 1**

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

**Not applicable**

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment or United Kingdom Technical Assessment has been issued:

This Declaration of Performance has been prepared in accordance with the guidelines set out within EAD 350454-00-1104 penetration seals and EAD 350141-00-1106 linear joint seals.

#### EU use only

- ETA 24/0364 and ETA 24/0365 prepared by UL
- CoC 2531-CPR-CXO10445 prepared by DBI Certification, notified body No. 2531

#### 9. Declared performance

Product type: <b>Acrylic</b>	Intended use: <b>Linear Joint &amp; Gap Seal and Penetration Seal</b>	
Essential characteristics	Performance	Harmonised Technical Specification or Test Standard
Reaction to Fire	B -s1 – d0	EN 13501-1
Resistance to Fire	EU - ETA-24/0364 and - ETA-24/0365 - Annex A	EN 13501-2
Air permeability	EU - ETA-24/0365 - Annex B	EN 1026
Water permeability	Not water proof	ETAG 026-3, Annex C
Release of dangerous substances	As the manufacture we declare that there is no release of dangerous substances during the installation or use of this product. See safety data sheets.	
Mechanical Resistance and stability	NPD	EOTA TR 001:2003
Resistance to impact/movement	NPD	EOTA TR 001:2003
Airborne sound insulation	R <sub>w</sub> = 62dB @ 12mm depth single sided w/o backing	EN 10140-2
Impact sound insulation	NPD	EN 10140-3
Thermal properties	0,0845 W/mK (+/-3%) @ 20mm depth	EN 12664, EN12667, EN12939
Water vapour permeability	NPD	EN ISO 12572, EN 12086
Durability and serviceability	Z <sub>2</sub>	ISO 8339:2005, ISO 9046:2004, ISO7389
Tensile properties	Elongation at break ≥100% @23°C	ETAG 026 pt2 B.13.5, ISO 8339:2005
Elastic recovery	7.5% Elongation 50% recovery, M2 Mortar	ETAG 026 pt2 B.13.5, ISO 7389:2003
Adhesion	No failure, M2 Mortar	EOTA TR 001:2003

10. The performance of the product identified in points 1 and 2 is in conformity with the performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed on the behalf of the manufacturer by:

**Name:** Stinne Sander

**Function:** Head of Product Management

**Place of Issue:** Vamdrup

**Date of Issue:** 6<sup>th</sup> December 2024

**Signature:** A handwritten signature in blue ink, appearing to read "Stinne Sander", written over a horizontal line.